



SEWER LINE ONLY
THE FOLLOWING GRADED BEDDING MATERIAL SHALL BE
USED IN WET TRENCH ONLY:

WATER LINE ONLY
THE FOLLOWING GRADED BEDDING MATERIAL SHALL BE
USED IN WET TRENCH ONLY:

WATER & SEWER LINE
THE FOLLOWING GRADED BEDDING MATERIAL SHALL BE
USED IN DRY TRENCH ONLY:

U.S. STANDARD SIEVE SIZE	PERCENT BY WEIGHT PASSING	U.S. STANDARD SIEVE SIZE	PERCENT BY WEIGHT PASSING	U.S. STANDARD SIEVE SIZE	PERCENT BY WEIGHT PASSING
1-1/2"	100%	3/4"	90 - 100%	1/2"	100%
1"	50-80%	3/8"	0 - 5%	NO. 4	90-100%
3/4"	30-60%			NO. 16	30-75%
3/8"	20-40%			NO. 200	0-10%
NO. 4	20-25%				
NO. 200	0-10%				

NO.	REVISION	DATE	GARDNERVILLE WATER COMPANY - STANDARD DETAILS	DRAWING NO.	
1	MISC. REVISIONS	09/12		G-1	
			TYPICAL TRENCH	DATE:	PAGE:
				12/98	1