



NOTE: ALL HYDRANT FLANGE BOLTS TO BE CHECKED PRIOR TO BACKFILL

FIRE HYDRANT, MUELLER A-423, WATEROUS WB67, OR AVK SERIES 27 (2) 2 1/2" OUTLETS AND (1) 4 1/2" OUTLET, SELF DRAINING BREAK-AWAY TYPE

DRAIN HOLE
 #4 ANCHOR BAR OR 1/4" GALVANIZED CHAIN
 CONCRETE THRUST BLOCK

THRUST BLOCKS BEHIND TEES AND HYDRANTS SHALL PROVIDE A MINIMUM BEARING OF 6 SQ. FT. AGAINST UNDISTURBED SOIL AND SHALL HAVE MIN. 2" CLEARANCE BELOW FLANGE. KEEP CLEAR OF DRAIN HOLES.

2 1/2" CLEAN CRUSHED DRAIN ROCK (2 CU. FT MIN.)

NO.	REVISION	DATE	GARDNERVILLE WATER COMPANY - STANDARD DETAIL	DRAWING NO.	
1	MISC. REVISIONS	09/12		G-3	
			FIRE HYDRANT DETAIL	DATE:	PAGE:
				12/98	3