



- NOTES: 1) CORPORATION STOP, CURB STOP AND SERVICE LINE SHALL BE THE SAME SIZE.
- 2) FLARED TYPE COUPLINGS SHALL BE USED AT ALL CONNECTIONS.
- 3) SERVICE CLAMPS SHALL BE SINGLE STRAP 1" SERVICES.
- 4) NO EXTENSIONS ARE ALLOWED ON METER PIT.
- 5) TOP OF METER PIT SHALL BE SET AT 0.2 FEET ABOVE ADJACENT GRADE.

NO.	REVISION	DATE	GARDNERVILLE WATER COMPANY - STANDARD DETAIL	DRAWING NO.	
1	MISC. REVISIONS	09/12	WATER SERVICE CONNECTION	G-5	
				DATE:	PAGE:
				12/98	5