


GARDNERVILLE WATER COMPANY - FIRE HYDRANT DETAIL (G-3)



NOTES:

- 1. ALL HYDRANTS SHALL HAVE 5-INCH INTEGRAL HYDRANT STORZ, OR APPROVED EQUAL, WITH BLIND CAP & CABLE, PER NDEP BSDW REQUIREMENTS.
- 2. ALL HYDRANT FLANGE BOLTS TO BE CHECKED PRIOR TO BACKFILL.

NO.	REVISION	DATE	GARDNERVILLE WATER COMPANY - STANDARD DETAIL	DRAWING NO.	
1	MISC. REVISIONS	09/12	FIRE HYDRANT DETAIL	G-3	
2	2022 UPDATES	09/22			
				DATE:	PAGE:
				09/22	3